PROPOSED EJECTOR PUMP

Approval will require the following conditions be met:

NJ Septic code: NJAC 7:9A-8.2 (c) The installation of an ejector pump requires the <u>septic field and</u> septic tank be oversized by 50%.

(TYPICAL – BUT, MAY NOT APPLY TO YOUR PROPERTY) A review of the documentation on file and/or submitted with your application shows that the current septic system serving the property, does NOT meet this requirement.

Some solutions, but not necessarily all-inclusive, are listed below:

- A NJ licensed engineer will need to show proof that the existing system meets septic code requirements;
- NJ licensed engineer to submit new application and plans to install the required 50% oversized septic tank and field to meet code requirements;
- NJ licensed engineer to submit new application and plans to install the required 50% oversized septic tank and apply to the NJDEP for a TWA to waive the requirement to meet the 50% oversized field.
- The use of a pump without a grinding component nor the capability nor intention of pumping solids is allowable only when accompanied by a certification from a licensed NJ PE that the alteration to the wastewater stream and discharge to the septic system will not affect the functioning of the existing septic. Typically, this step will include a septic evaluation and report from a professional septic evaluator.

Any documentation provided by an engineer must be hard copy and sealed with the engineer's stamp. Please contact a NJ licensed engineer for further guidance in meeting the code requirements.

Gravity plumbing requires no additional requirements.

Please advise how you wish to proceed. Your prompt response is requested.

Candice Morgan, REHS
Senior Registered Environmental Health Specialist
cmorgan@sussex.nj.us
schealth@sussex.nj.us

Sussex County Department of Health and Human Services

Lin mess

Division of Health 201Wheatsworth Road Hamburg NJ 07419 Tel: (973)-579-0370 Fax: (973)-579-0399